



Notes:

1. 10 and 100 Year design flows are based on the Sacramento Method.
2. If the County determines that the storm drain is a special case, the pipe design 10 Year HGL is based on the Sacramento Method.
3. The 10 Year HGL must be 0.5 feet below the drop inlet.
4. The 100 Year HGL must be 1.0 feet below the house pad.
5. For areas adjacent to the creek, the house pads must be set at a minimum of 1.0 feet above the 100-year floodplain elevation.

Date **December 1996**

Figure **2-1**

County of Sacramento Design Runoff Criteria All Development